



AMENDMENT-II

IFB no. AEGCL/MD/TECH-763/PTR/AP/2018-19/IFB

Bid Identification No. AEGCL/MD/TECH-763/PTR/AP/2018-19/BD

The bid identified against the above referred IFB and Bid identification no. is amended to the following extent -

1. Section-3, Purchaser's Requirements

The Clause 3.21.2.8 is amended to read as follows:

" There shall be individual remote control panel(Digital RTCC) for remote operation of on load tap changing gears. Each of the panels shall be suitable for **atleast 2(two) transformers.**

Following accessories and indication shall be mounted in remote control panel complete with all internal wiring etc:-

- i) Raise and lower push button switch.
- ii) Remote tap position indicator.
- iii) Transformer voltage ratio indicator.
- iv) Illumination signal when Transformers are out-of-step (Under parallel operation.)
- v) Indicating lamp showing tap change in progress.
- vi) Illumination signal when tap change is in complete. (With separate contacts for audible alarm in the main communication panel of Sub-Station)
- vii) Remote electrical winding temperature indicator with 4-20mA output signal for SCADA
- viii) A five digit counter to indicate the number of operation completed by the equipment.
- ix) "Master", " follower" and " independent" lockable selector switch.
- x) All the above points i.e. from i) to ix), signals shall be extended to local SCADA, for control, and status indications as such necessary provisions shall have to be considered.
- xi) Any other item manufacturer considered necessary.

The complete particulars of tap changing gears including all accessories shall be furnished with shall be provided. "

The requirement of Digital RTCC Panels under this package shall be as follows:

- a) For 1(one) transformer at Sipajhar GSS - 1 no. of panel
- b) For 2(two) transformers at Dhemaji GSS - 1 no. of panel
- c) For 2(two) transformers at Rowta GSS - 1 no. of panel
- d) For 1(one) transformer at Ghoramari (location may be changed at the time of issuing Dispatch Clearance) GSS - 1 no. of panel

All other terms and conditions shall remain same.

The tender submission deadline is extended upto 12:00 Hrs. of 13.09.2018.

Tender opening date : 14:00 Hrs of 14.09.2018

Sd/-

Chief General Manager
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513
Web: www.aegcl.co.in

Memo No. AEGCL/MD/TECH-763/PTR/AP/2018-19/16

Dtd: 01.09.2018

Copy to :

1. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website. (Soft copy enclosed)

Paban Kumar
1.9.18

Chief General Manager
Assam Electricity Grid Corporation Ltd

rk