



## **ASSAM ELECTRICITY GRID CORPORATION LIMITED**

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513  
Web: [www.aegcl.co.in](http://www.aegcl.co.in) Email: [managing.director@aegcl.co.in](mailto:managing.director@aegcl.co.in)

---

### **Corrigendum-II**

IFB No. AEGCL AEGCL/MD/Tech-652/200,160 MVA TR/AP&NEC/01/IFB  
Bid identification No. AEGCL AEGCL/MD/Tech-652/200,160 MVA TR/AP&NEC/01

Following amendments are hereby made to Bid Document:

**Clause 3.11.1.5**

For 160 MVA transformer voltage variation shall be +10% to -10%.

**Clause 3.25.2, Sl. No. 7**

160 MVA transformers is constant percentage impedance type.

All other terms and conditions remain same.

Yours faithfully

(U N Bora)  
Chief General Manager, AEGCL