



ASSAM ELECTRICITY GRID CORPORATION LIMITED
Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513
Web: www.aegcl.co.in Email: managing.director@aeqcl.co.in

CORRIGENDUM-I

IFB no.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/IFB
Bid No.: AEGCL/MD/PSDF-017/DIAGTOOLS(Retender)

The completion time for “**Supply of Diagnostic Tools and Related Services for Various Substations of AEGCL under PSDF (Retender)**” against above referred IFB is revised to **3(three) months**.

Bidders are requested to note the same before submitting their tender.

All other terms and conditions of the tender remain unaltered.

Asan Khandu
20-11-18

Chief General Manager
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1

Memo No.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/ 04

Dtd: 20.11.2018

Copy to:

- 1) The AGM-IT for publishing of notice in AEGCL website.

Asan Khandu

Chief General Manager, AEGCL



Memo No.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/ 05

Dtd: 20.11.2018

Corrigendum Notice: I

IFB no.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/IFB
 Bid No.: AEGCL/MD/PSDF-017/DIAGTOOLS (Retender)

Following amendments are made to the bidding document for **“Supply of Diagnostic Tools and Related Services for Various Substations of AEGCL under PSDF (Retender)”**

Sl. No.	Clause ref	Description	Existing clause	Amended clause
1	3.5.0(2)	(2)Technical Specification for SF6 Gas Leakage Detector:	(4) Sensor Sensitivity: 1 ppmv No cross sensitivities to other gases. Moisture: unaffected from 0-100% relative humidity(non condensing)	Sensor Sensitivity: 5 g SF6/ year or less No cross sensitivities to other gases Moisture: unaffected from 0-100% relative humidity(non condensing)
2	3.5.0(5)	(5)Technical Specification for Dissolved Gas Analyzer (portable)	(8) consumable gases (9) DGA diagnostic features (10) Settable limits (11) Display (17) In-built Printer	Clauses deleted
3	3.5.0(5)	(5)Technical Specification for DGA (portable)- (20) calibration	New clause	If calibration is required :- a). Instrument shall have facility to perform calibration check using GAS-IN-OIL standards as well as calibration gas mixtures. This GASIN-OIL standard shall be prepared in syringes in accordance with IEC-60567- 2005 - Page No.35- clause 6.2. b). The calibration shall be demonstrated by supplier at the time of installation/commissioning at our lab and AEGCL will provide only the insulating oil for testing. c). All necessary requirement like Glass syringes, 3 way cock and any other consumable required for calibration check shall include in the scope of supply.
4	3.5.0(5)	(5)Technical Specification for DGA (portable)- 15(Internal memory)	The internal memory should be capable to storing minimum 1000 records	Equipment should be capable of storing records in internal memory/SD card

Tender submission deadline is hereby extended upto **12:00 Hrs on 27.11.2018.**

Rasom h...
20.11.18

Chief General Manager
 Assam Electricity Grid Corporation Ltd
 Bijulee Bhawan, Paltanbazar, Guwahati – 1

(Signature)