

PUBLIC NOTICE

Snapping of Conductor and failure of Surge Arrester at Power Grid Corporation Of India Limited's Misa Grid Sub Station at 7.22 Hrs of 14.09.2009 has led to cascade tripping of entire Upper Assam Grid including Generating Stations of Kathalguri, Kopili, Lakwa TPS and forced Namrup TPS to operate in isolation.

This resulted to a shortfall of around 300 MW in ASEB System and regrettably forced ASEB to enforce load shedding. ASEB's Lakwa TPS had already been brought back to service at 11.00 hours. Central Sector Power Stations at Kathalguri and Kopili are on with partial load.

Power Grid Corporation of India Limited is working at their Misa Grid Substation on war footing basis.

Esteemed consumers of ASEB are requested to bear the inconvenience caused.