



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513
Web: www.aegcl.co.in Email: managing.director@aegcl.co.in

AM. ENDMENT

IFB no. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/25
BID IDENTIFICATION NOS. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/24

The bids identified against the above referred IFBs and Bid identification nos. is amended to the following extent -

1. Section-3, Employer's Requirements

a (vi) of Sub Clause No. 3.16.1.12.1 under Page No. 46 may be read as follows: -

Tan delta and capacitance measurement (For only 33kV current transformer, tan delta and capacitance test point not required)

All other terms and conditions shall remain same.

Chief General Manager(PP&D)
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1

Memo No AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/ 36
Copy to :

Dtd : 05.11.2018

1. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website. (Soft copy enclosed)

Chief General Manager(PP&D)
Assam Electricity Grid Corporation Ltd