



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513

Web: [www.aegcl.co.in](http://www.aegcl.co.in)

No. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt File(Cable)/6

Dtd: 23 .10.2019

## CORRIGENDUM

IFB No. AEGCL/MD/ Tech-635/PTR/40MVA/AP&NEC/Pt File(Cable)/IFB dtd 15.10.2019


Bid Identification No. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt File(Cable)/Bid

The bid identified against the above referred IFB and Bid identification no. is amended to the following extent -

**Section - 3, Employer's Requirements, Cl. No. 3.16.1.1.7.1 : General, SI No. (f) may be read as follows:**

" f) For control, cables only round wire armouring shall be used. "

*All other terms and conditions shall remain same.*

  
Chief General Manager(PP&D)  
Assam Electricity Grid Corporation Ltd  
Bijulee Bhawan, Paltanbazar, Guwahati – 1

Memo No : AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt File(Cable)/6(a)

dtd: 23. 10. 2019

Copy to:-

1. The AGM-III, HQ, AEGCL : -for necessary action for uploading on AEGCL's website.

  
Chief General Manager (PP&D).