



**ASSAM ELECTRICITY GRID CORPORATION LIMITED**  
Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513  
Web: [www.aegcl.co.in](http://www.aegcl.co.in) Email: [managing.director@aegcl.co.in](mailto:managing.director@aegcl.co.in)

Memo No.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/19

Dtd: 15/12/18

**Corrigendum Notice: III**

IFB no.: AEGCL/MD/Tech- 649/DIAGTOOLS/(Retender)/IFB  
Bid No.: AEGCL/MD/PSDF-017/DIAGTOOLS (Retender)

Following amendments are made to the bidding document for "**Supply of Diagnostic Tools and Related Services for Various Substations of AEGCL under PSDF (Retender)**"

Sl. No.	Clause ref	Description	Existing clause	Amended clause
1	3.5.0(2)	(2)Technical Specification for SF6 Gas Leakage Detector:	Sensor Sensitivity: <b>5 g SF6/ year or less</b> No cross sensitivities to other gases Moisture: unaffected from 0-100% relative humidity(non condensing)	Sensor Sensitivity: <b>5 g or less SF6/ year</b> No cross sensitivities to other gases Moisture: unaffected from 0-100% relative humidity(non condensing)
2	3.5.0(4)	(5)Technical Specification for Karl Fischer Oil Testing Kit	Measuring range for KF - 10 µg - 10mg	Measuring range for KF - 1µg - 10 mg/1ppm-100 ppm

**Regarding calibration of equipment it is clarified that** "Unit shall be duly calibrated at/traceable to accredited laboratory (accredited by NABL/Indian Govt. Agency/recognized international accreditation body) before supply and the date of calibration shall not be older than two months from the date of supply of the kit". GTP forms should be read accordingly

Tender submission deadline is hereby extended upto **12:00 Hrs on 18.12.2018**. Techno commercial bids shall be opened at **14:00 hrs. on 19.12.2018**

All other terms and conditions of the bidding document remain same.

*Paban Kumar*  
15-12-18

Chief General Manager  
Assam Electricity Grid Corporation Ltd  
Bijulee Bhawan, Paltanbazar, Guwahati - 1

*19*