



**ASSAM ELECTRICITY GRID CORPORATION LIMITED**  
**OFFICE OF THE MANAGING DIRECTOR**

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520  
Web: [www.aegcl.co.in](http://www.aegcl.co.in)

FAX NO.0361-2739513  
Email: [managing.director@aeqcl.co.in](mailto:managing.director@aeqcl.co.in)

No. AEGCL/MD/Tech-798/RVNL/Bar-Sor/Cable/2019/18

Dtd:20.03.2018

**Corrigendum- I**

IFB No. AEGCL/MD/Tech-798/RVNL/Bar-Sor/Cable/2019/14  
BID Identification No. AEGCL/MD/RVNL/BAR-SOR/CABLE/BID

**“Turnkey Construction of 132 kV s/c Transmission link from Sorbhog Railway Traction s/s to Tower No. 1 of 132 kV Barnagar - Sorbhog transmission line”.**

Following amendments are made to the bidding document:

SL	Ref No.	Existing Clause	Amended Clause
1	Schedule 2 of BOQ ETC including foundation  SI No. 15	New Item	<b>Gravelling</b> of area covering gantry structure, LA and cable termination structure at tower end. Laying of 100mm thick gravelling, with 40mm size of gravel complete with supply of all materials and labour. Leveling of ground and Spraying of anti-weed chemicals also included.
2	Bid Document Clause 4.9 & Clause 4.28.2 SI No.20	Depth of Laying of Cable	Minimum Depth for cable laying should be as follows: <b>1) 3m in case of HDD</b> <b>2) 1.5m in case of cable trench</b> However, actual depth of cable laying will be as per actual site condition and depending upon the route survey carried out by the successful bidder during execution.

Bidders should also note the following:

- 1) Single end bonding system for Cable is preferred; however, the final bonding will depend upon the survey as per actual site condition.
- 2) Trefoil formation for cable laying shall be adopted; however, the final formation will depend upon the survey as per actual site condition.

All other terms and conditions shall remain same.

**-sd/-**

**Chief General Manager (T&T)**  
Assam Electricity Grid Corporation Ltd



**ASSAM ELECTRICITY GRID CORPORATION LIMITED**  
**OFFICE OF THE MANAGING DIRECTOR**

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520  
Web: [www.aegcl.co.in](http://www.aegcl.co.in)

FAX NO.0361-2739513  
Email: [managing.director@aeqcl.co.in](mailto:managing.director@aeqcl.co.in)

---

Memo No. AEGCL/MD/Tech-798/RVNL/Bar-Sor/Cable/2019/18(a-b)

Dtd: 20.03.2019

Copy to:

1. The Managing Director, AEGCL for favour of his kind information.
2. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website.  
(Soft copy enclosed)

**-sd/-**

**Chief General Manager (T&T)**  
Assam Electricity Grid Corporation Ltd