



## ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513

Web: [www.aegcl.co.in](http://www.aegcl.co.in) Email: [managing.director@aegcl.co.in](mailto:managing.director@aegcl.co.in)

### Amendment

Bid Reference No. AEGCL/MD/TECH-652/ 200,160MVATR/AP&NEC/01/IFB

The following amendments are made in the bid for "Supply of 220/132/11 kV, 200 MVA, and 160MVA Auto Transformers and Related Services for Sarusajai & Salekathi Grid Substations in Assam" of AEGCL.

- The following clause is added in Item SI No 4 of clause 3.27 (List of Equipments) of employers requirement.  
"The Make and model of Automatic Capacitance & Tan Delta measurement kit should be Megger 4110 or equivalent Omicron Make."
- Clause 3.25.2, SI-15 may be read as

15	a) Percentage Impedance at 75°C for 200 MVA (HV-IV)	10.3% (Max. tap), 12.5% (Nor tap), & 15.4% (Min. tap)
	b) Percentage Impedance at 75°C for 160 MVA (HV-IV)	9.68% (Max tap), 9.70% (Nor tap), 10.14% (Min tap)
	c) Percentage Impedance at 75°C for 200 MVA & 160MVA (HV-LV) & (IV-LV)	45% & 30%

- The clause 3.11.1.5 should be read as  
"The 200 MVA transformers shall be capable of being operated, without danger, on any tapping at the rated MVA with voltage variation of 132 kV from (-) 5% to (+) 15% in 16 equal steps corresponding to the voltage of the tapping. And the 160 MVA transformers shall be capable of being operated, without danger, on any tapping at the rated MVA with voltage variation of 220 kV from (-) 5% to (+) 15% in 16 equal steps corresponding to the voltage of the tapping."
- Clause 3.14.2.3  
"Coil clamping rings, if provided shall be of fibre glass or wood."
- Clause 3.17.2.5  
"Five numbers of probes shall be provided in fibre optics channel."
- The bid submission and opening time are rescheduled as below.  
Tender end date and time: 12:00 hrs of 19.09.2016  
Tender opening date and time: 13:00 hrs of 19.09.2016

Chief General manager  
Assam Electricity Grid Corporation Ltd

Memo No AEGCL/MD/TECH-652/ /200,160 MVATR/AP & NEC/ 06  
Copy to :

Dtd : 07.09.2016

- 1 The AGM -IT, O/o the MD, AEGCL, for publication of the IFB & bid document in AEGCL's Website. (Soft copy enclosed)
2. The AGM(F&A), AEGCL for information and necessary action.
3. The Deputy Manager(PRO), O/o the MD, AEGCL for publication of the NIT in The Assam Tribune, Dainik Agradoot and The Business Standard(Delhi Edition).

Chief General Manager, AEGCL