



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513  
Web: [www.aegcl.co.in](http://www.aegcl.co.in) Email: [managing.director@aegcl.co.in](mailto:managing.director@aegcl.co.in)

## AMMENDMENT

IFB no. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/25  
BID IDENTIFICATION NOS. AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/24

The bids identified against the above referred IFBs and Bid identification nos. is amended to the following extent -

### 1. Section-2, Bidding Forms

The text appearing at Sl. 1. (A) of Schedule No: 1 Supply of Goods of Price Schedule form is amended to read as follows:

Supply of live / dead tank type Current Transformer (1-phase) for 40MVA Transformer(s). with all fittings and accessories including terminal connectors, marshalling box etc. as per specification, rated extended primary current 1.5 times.

### 2. Section-2, Bidding Forms

The text appearing at Sl. 1. (B) of Schedule No: 1 Supply of Goods of Price Schedule form is amended to read as follows:

Supply of live / dead tank type Current Transformer (1-phase) for Line(s). with all fittings and accessories including terminal connectors, marshalling box etc. as per specification, rated extended primary current 1.5 times.

### 3. Section-2, Bidding Forms

The text appearing at Sl. 1. (A) of Schedule No: 1A Freight and Insurance of Goods of Price Schedule form is amended to read as follows:

Supply of live / dead tank type Current Transformer (1-phase) for 40MVA Transformer(s). with all fittings and accessories including terminal connectors, marshalling box etc. as per specification, rated extended primary current 1.5 times.

### 4. Section-2, Bidding Forms

The text appearing at Sl. 1. (B) of Schedule No: 1A Freight and Insurance of Goods of Price Schedule form is amended to read as follows:

Supply of live / dead tank type Current Transformer (1-phase) for Line(s). with all fittings and accessories including terminal connectors, marshalling box etc. as per specification, rated extended primary current 1.5 times.

### 5. Section-3, Employer's Requirements

A sub clause is amended to the clause 3.16.1.3 **General Requirements** which read as follows:

"3.16.1.3.2 Instrument transformers shall be of Live / Dead Tank design"

*All other terms and conditions shall remain same.*



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513  
Web: [www.aegcl.co.in](http://www.aegcl.co.in) Email: [managing.director@aecl.co.in](mailto:managing.director@aecl.co.in)

**Chief General Manager(PP&D)**

Assam Electricity Grid Corporation Ltd

Bijulee Bhawan, Paltanbazar, Guwahati – 1

Memo No AEGCL/MD/Tech-635/PTR/40MVA/AP&NEC/Pt-III/28

Dtd : 21.10.2018

Copy to :

1. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website. ( Soft copy enclosed)

**Chief General Manager(PP&D)**

Assam Electricity Grid Corporation Ltd