



AMENDMENT & BID SUBMISSION DUE DATE EXTENSION

IFB no.: AEGCL/MD/Tech-681/PSDF/NIFPS(PackageA)/IFB dtd. 30.05.2019
Bid No.: AEGCL/MD/PSDF-025/NIFPS/BD/R (Package A)

With reference to the pre-bid discussion dtd. 19.06.2019, on tender for "Supply, installation, testing & commissioning of Nitrogen Injection Type Fire Prevention & Extinguishing System at various substations under LAZ of AEGCL under PSDF(Package A)" the following amendment/clarifications are given to the bidding document:

1) The clause 3.3.0 and its sub-clauses are amended as below-

3.1.0 TEST REPORTS

- 3.1.1. *Equipment, which have never been tested for critical performance, shall not be accepted. In such cases, a promise or agreement by a bidder to have the equipment tested after award of a contract is not acceptable.***
- 3.1.2. *All Bids must be accompanied by the full Test Certificates of equipment offered. Such test certificates shall be acceptable only if: -***
- (a) Tests are conducted in an independent and well known testing laboratory, or
- (b) Tests are conducted in manufacturer's own laboratory. In this case (i) the laboratory must have ISO 9000 (or its equivalent) series certification; and (ii) tests have been witnessed by technically qualified representatives of earlier clients or purchaser.
- 3.1.3. *Test reports to be acceptable must be related directly to the materials offered.***
- 3.1.4. *Test Reports older than five (5) years on the date of Technical bid opening shall not be accepted.***
- 3.1.5. This clause has reference to bid document Clause 2.3.3, Appedix-2 of ITB, Section-1, 'Evaluation and Qualification Criteria'.**

2) Clause 1.3.3.2(g) – 'type test report' is replaced by 'test report'.

3) Form Exp-2 - 'type test report' is replaced by 'test report'.

4) Clause 1.6.1.1 award criteria amended as –

Purchaser shall in general award the contract to the lowest substantially responsive bidder. However, the purchaser reserves the right to not award contract for the items to the lowest substantially responsive bidder and/or split the order at L1 rate without thereby incurring any liability to Bidders.

All other terms and conditions of the bid remain same.

Bid submission deadline is hereby extended upto 12:00 Hrs. of 29.06.2019.

Braraj
25/06/19
(Smt. P Handique Baruah)
Chief General Manager (PP&D), AEGCL

Memo No.: AEGCL/MD/Tech-681/PSDF/NIFPS/ 75
Copy to:

Dtd: 25.06.2019

- 1) The AGM-IT for publishing of the notice in AEGCL website.

Braraj
25/06/19
Chief General Manager (PP&D), AEGCL