



ASSAM ELECTRICITY GRID CORPORATION LIMITED
Regd. Office: 1st Floor, Bijulee Bhawan, PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238
PHONE: 0361-2739520 FAX NO.0361-2739513
Web: www.aegcl.co.in Email: managing_director@aegcl.co.in

Amendment

Bid identification no:- AEGCL/MD/TECH-635/ /PTR/40 MVA/AP & NEC/01

The following amendments are made in the bid for “**Supply of 40 MVA, 132/33 kV Power Transformers with Related Services for Various Grid Substations in Assam**” of AEGCL.

1. The following clause is added in section -3 of employer’s requirement

Cl 3.15.2.1 (Xii) “The conservator tank shall be of standalone type and should not be riveted/ clamped/attached with the main tank.”

2. **The bid submission and opening time are rescheduled as below.**

Tender end date and time: **12:00 hrs of 23.08.2016**

Tender opening date and time: **13:00 hrs of 23.08.2016**

Managing Director
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1