



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238

PHONE: 0361-2739520 FAX NO.0361-2739513
Web: www.aegcl.co.in Email: managing.director@aegcl.co.in

Corrigendum

IFB No.: AEGCL/MD/Tech-715/200 MVA TR/AP/17-18/IFB dtd. 19 .05.2017
Bid Identification No.: AEGCL/MD/TECH-715/ /200 MVA TR/AP/17-18/BD

The following amendments are made in the bid for "Supply of 220/132/11 kV, 200 MVA Auto Transformer and Related Services for Sarusajai Grid Substation in Assam" of AEGCL.

1. Transformer parameter in Clause **3.25.2, SI-15(b)** is to be read as

15	b) Percentage Impedance at 75°C for 200 MVA transformer (HV-LV) & (IV-LV)	45% & 30%
----	---	-----------

All other terms and conditions of the bidding document remain same.

Sd/

Chief General Manager
Assam Electricity Grid Corporation Ltd