



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in



CORRIGENDUM - II

IFB No. : AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/IFB
Bid Identification No. AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/BID

The bid identified against the above referred IFB and Bid identification no. is amended to the following extent -

I. Section-3, Purchaser's Requirements

1. The clause **Section-3, Clause No.3.27.2.11(a)** is amended to be read as follows:

11(a). The loss figures (both guaranteed & test) for the purpose of this clause shall be at rated frequency and voltage and at principal tap and 75° C.

Maximum losses:

While the bidders may offer their own design, the maximum limit of losses which include tolerance, but Standard Fixed Losses for Transformers and Shunt Reactors as per Central Electricity Authority (CEA) letter CEA/PSE&TD/218/3056-4028 dated 01.03.19 shall be as below:

No Load Loss (kW)	Load Loss (kW)	I ² R (kW)	Stray + Eddy (kW)	Aux. Loss (KW)
AT 25	125	105	20	3

All other terms and conditions shall remain same.

Amend 20-11-20
for
Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati - 1

Memo No : AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/ 21

dtd: 20.11.20

Copy to:-

1. The AGM-III, HQ, AEGCL :- for necessary action for uploading on AEGCL's website.

Amend 20-11-20
for
Chief General Manager (PP&D)