



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR
Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR, GUWAHATI - 781001
CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3
PHONE: 0361-2739520 Web: www.aegcl.co.in



CORRIGENDUM

IFB No. : AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/IFB
Bid Identification No. AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/BID

The bid identified against the above referred IFB and Bid identification no. is amended to the following extent -

I. Section-3, Purchaser's Requirements

1. The clause **Section-3, Clause No.3.27.2.11(a)** is amended to be read as follows:

11(a). The loss figures (both guaranteed & test) for the purpose of this clause shall be at rated frequency and voltage and at principal tap and 75° C.

Maximum losses:

While the bidders may offer their own design, the maximum limit of losses which include tolerance, but Standard Fixed Losses for Transformers and Shunt Reactors as per Central Electricity Authority (CEA) letter CEA/PSE&TD/218/3056-4028 dated 01.03.19 shall be as below:

No Load Loss (kW)	Load Loss (kW)	I ² R (kW)	Stray + Eddy (kW)	Aux. Loss (KW)
AT 25	95	76	20	3

2. The clause **Section-3, Clause No.3.27.2.2** is amended to be read as follows:

" Rating (MVA) - 50"

3. The clause **Section-3, Clause No.3.27.2.9** is amended to be read as follows:

" Rating at different cooling in % - 80/100 (ONAN/ONAF)"

II. For reference of the bidder, a copy of the General Conditions of Supply and Erection, 2009 of AEGCL is attached as Annexure.

All other terms and conditions shall remain same.

Chief General Manager(PP&D)
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati - 1

Memo No : AEGCL/MD/Tech- 861/50MVA/TR(2)/AP/2020-21/18

dtd: 18.11.20

Copy to:-

1. The AGM-III, HQ,AEGCL :for necessary action for uploading on AEGCL's website.

Chief General Manager (PP&D)