



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Office: 1st floor, Bijulee Bhawan, Paltan Bazar, Guwahati-781001

CIN: U40101AS2003SGC007238

Phone: 0361-2739520/ Fax: 0361-2739513 web: www.aegcl.co.in

No. AEGCL/DGM(CIVIL)/Tech-61(Part-23)/2019-20/533

Dtd.27-02-2020

CORRIGENDUM-I

REF: NIT NO: AEGCL/DGM (Civil)/2019-20/27 Dated. 19/02/2020

Name of Work:- “Renovation of first floor (west side) of Bijulee Bhawan including workstation”.

A Pre-bid meeting is held on 26-02-2020 as per the provision of the Cl. No.(A) (10) (a) of the bidding document. The members representing AEGCL and the prospective bidders discussed on the various clarifications and clauses of the bid document and the minutes of the meeting are as follows:

1. The useable material obtained after dismantling of the work area must be handed over to AEGCL. However, any waste material obtained during the dismantling and demolishing shall be disposed off outside Bijulee Bhawan campus by the contractor. (Clause no. 1.01 of BOQ)
2. It must be noted that rollers should be used for painting. Also, the brand and specification of paint will be provided by AEGCL in due course of time. (Clause no. 1.10 of BOQ)
3. There shall be glass film imprinting AEGCL’s logo in the two entrance doors of the work area. (Clause no. 1.15 of BOQ)
4. Gypsum should be provided on the periphery of the entire area drawn down from the main ceiling section. (Clause no. 1.16 of BOQ)
5. Toilet napkin dispensers must be provided near basins instead of toilet paper holder. (Clause no. 1.22 of BOQ)
6. Cable raceway is to be provided along the floor for laying of cables and also for future scope of work. All associated work will be under the scope of contractor as complete job basis.
7. All block board and ply materials should be waterproof. (Clause no. (F) (f) (i), (ii) & (iii) of Bid document)
8. 2 (two) units shall be made with HDHMR materials for experimental purpose and no extra cost will be provided for the same.
9. 10 mm toughened glass is to change to 6 mm clear glass for small cabinet partitions. The DGM cabinet shall be made with toughened glass as per the bid document. (Clause no. (F) (f) (x) of Bid document)
10. Locks should be provided with three number of keys. All the keys and necessary warranty documents, if any, must be submitted to AEGCL at the time of taking over by AEGCL.
11. All the top working area of the workstation shall be covered with glass with minimum wastage. The cost of glass must be included with the workstation. No extra payment will be made for same. The colour of the glass and design will be approved by AEGCL in due course of time.
12. The contractors are required to submit detailed time schedule within 7 days of issue of work order which shall be approved by AEGCL. Since multiple contractors will be working at the same location, contractors will have to follow strict timeline as AEGCL’s approved schedule so as to carry out the works in a synchronized manner. No deviation from the timeline shall be acceptable.

All other terms and condition of the Bid Document shall remain same and unaltered.

sd/-

Chief General Manager (O&M)
Assam Electricity Grid Corporation Limited.
Bijulee Bhawan, Paltan Bazar, Guwahati-1