



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR, GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in



No. AEGCL/MD/AIFA/Tech-489/2011-12/HTLS/IFB/Extn/04

Dtd: 27.08.2019

Notice on 'Extension cum Additional Corrigendum of Bid'

IFB No. AEGCL/ AEGCL/MD/AIFA/Tech-489/2011-12/HTLS/IFB dtd 07.08.2019

Bid Identification No. AEGCL/MD/AIFA/HTLS/NATHKUCHI/2019/Bid

The last date of submission for the Bid identified against the above referred IFB and Bid identification no. is Extended and the Bid is further amended to the following extent:


[A] Following amendments are made to the bidding document :

1. In Section 1 & Section-2 of Vol-II and anywhere in this Bid, the word "ACCC" shall stand amended as "Solid Carbon Core HTLS or equivalent Conductor"
2. In Section 2.5.1 of Vol-II, under Minimum Criteria to be met, the words - ".....which are in successful operation for at least five (5) years...." for all the three rows in the table shall stand amended as "...which are in successful operation in India for at least two (2) years....."
3. In Section 2.7.1 under Type test, the following para shall be deemed to be included – The Type Tests conducted should be in conformity with the standards of ASTM or equivalent standards for the conductor

[B] The Last Date for submission of the Bid is hereby extended up to **14:00 hrs of 06/09/2019**. Tender will be opened at **14:00hrs on 07/09/2019**.

All other terms and conditions shall remain same.


Bidders are requested to note the same before submitting their tender.


Chief General Manager (PP&D),
AEGCL

Memo No. AEGCL/MD/AIFA/Tech-489/2011-12/HTLS/IFB/Extn/04(a) Dtd:

Copy to:

1. The Managing Director, AEGCL for favour of his kind information.
2. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website.
(Soft copy enclosed)


Chief General Manager (PP&D),
AEGCL