

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in



Date: 16.10.2023

No. AEGCL/MD/PRE BID QUERY/RANGIA-Pkg G/2023-24/48

Addendum-II of the tender document Tender No: AEGCL/MD/AIIB/PACKAGE-G/2022/01-G

Tender Details/Name of work: Construction of 400/220/132/33kV GIS, with transformation ratio of 400/220kV, 2x500 MVA; 220/132kV, 2x160 MVA; 132/33kV, 2x50 MVA at Rangia with associated Transmission Lines, along with bay extension works at existing 132/33kV Nalbari GSS (Package G)

Table 2: Volume-II Chapter 16: TECHNICAL SPECIFICATIONS FOR GIS EQUIPMENTS & EOT CRANE

| S. No | Clause No | As Existing | | As Amended | | Reference to SI. No. of Response [Table 1] wherever applicable |
|----------|---------------|-------------|--|------------|-----------------------------------|--|
| 1 | Clause 16.2.2 | | | | | MOM point of Table-1, |
| | | 400 kV GIS | Single phase enclosed | 400 kV GIS | Single phase enclosed | Chapter 16, sl no. 1 may pl be ignored |
| | | 220kV GIS | kV GIS Single Phase/Three Phase enclosed Bus Bar (Single Phase enclosed) | 220kV GIS | Single Phase/Three Phase enclosed | |
| | | | | 132 KV GIS | 2 KV GIS Three Phase enclosed | |
| | | | | | | |
| | | 132 KV GIS | Three Phase enclosed | | | |



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR
Regd. Office:(1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in



Table 2: Volume-II Chapter 32: MANDATORY SPARES

| Sl. | Clause No. | As Existing | As Amended | Reference to Sl. No. of |
|-----|---------------|---|--|-------------------------|
| No | | | | Addendum [Table 2] |
| | | | | wherever applicable |
| 1 | 32.14 SPECIAL | Portable Partial Discharge monitoring with laptop and software Make Qualitrol | Portable Partial Discharge monitoring with laptop and software (at least 8 | |
| | TOOLS AND | Model No. QCM-PPDM | channels) Make Qualitrol Model No. QCM-PPDM/Megger Model: Power | |
| | KITS | | Diagonistic | |

Table 2: Price Schedule (BOQ)

| Sl. | Clause No. | As Existing | As Amended | Reference to Sl. No. of |
|-----|-----------------|---|---|-------------------------|
| No | | | | Addendum [Table 2] |
| | | | | wherever applicable |
| 1 | BoQ – | SFRA kit Make: Dobble, Model: M5400 | SFRA kit Make: Dobble, Model: M5400/Megger SMRT 410 | |
| | Mandatory | | | |
| | Spares-Item no. | | | |
| | 26.071 | | | |
| 2 | BoQ – | Relay testing kit Omicron CMC 356 with complete softwares for testing | Relay testing kit Omicron CMC 356/Megger with complete softwares for | |
| | Mandatory | Diiferential, Distance, Auto-recloser, Over voltage, Overcurrent, Advance | testing Diiferential, Distance, Auto-recloser, Over voltage, Overcurrent, | |
| | Spares-Item no. | distance, Advance differential etc. along with relay management softwares. | Advance distance, Advance differential etc. along with relay management | |
| | 26.042 | | softwares. | |
| 3 | BoQ – | Portable Partial Discharge monitoring with laptop and software Make Qualitrol | Portable Partial Discharge monitoring with laptop and software (atleast 8 | |
| | Mandatory | Model No. QCM-PPDM | channels) Make Qualitrol Model No. QCM-PPDM/Megger Model: Power | |
| | Spares-Item no. | | Diagonistic | |
| | 26.006 | | | |



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001 CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in



Table 2: Volume-II Chapter 7: GENERAL TECHNICAL CLAUSES FOR DESIGN

| Sl. No | Clause No. | As Existing | As Amended | Reference to Sl. No. of Addendum [Table 2] wherever applicable |
|-----------|------------|-------------|--|--|
| 1 | | | New Clause added: Cyber Security All Intelligent electronic equipment, Numerical relays, Bay control units, Bay protection units, Gateways, Transformer Tap controller/changer, etc. with IEC 61850 communication protocol shall be cyber security compliant as per latest "CEA (Cyber security in power sector) Guidelines". Specifications shall also be complaint to latest revision of IEEE 1686. | |

-Sd-

Project Director (AIIB), AEGCL