

**ASSAM ELECTRICITY GRID CORPORATION LIMITED**

OFFICE OF THE MANAGING DIRECTOR
Regd. Office: (1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3
PHONE: 0361-2739520 Web: www.aegcl.co.in



No. AEGCL/MD/PRE-BID QUERY/RANGIA-Pkg G (R)/2023-24/03

Date: 26.12.2023

Addendum-I of the tender document Tender No: AEGCL/MD/AIIB/PACKAGE-G(R)/2023/01-G (R)

Tender Details/Name of work: **Construction of 400/220/132/33kV GIS, with transformation ratio of 400/220kV, 2x500 MVA; 220/132kV, 2x160 MVA; 132/33kV, 2x50 MVA at Rangia with associated Transmission Lines, along with bay extension works at existing 132/33kV Nalbari GSS (Package G(R))**

TABLE: 2 (VOLUME-1)

Sl No.	Clause No.	As Existing	As Amended	Reference to Sl. No. of Response [Table 1] wherever applicable
1	Section 2: Tender Data Sheet (TDS): ITT 11.2 (k)	The Tenderer (for single as well as Joint venture entity) shall submit with its tender the following additional documents: i. Valid Electrical (HT/EHT) license issued by the Authority anywhere in India.	The Tenderer (for single as well as Joint venture entity) shall submit with its tender the following additional documents: i. Valid Electrical license issued by the Authority anywhere in India.	<u>TABLE-1(A)</u> : Sl No. 2

**ASSAM ELECTRICITY GRID CORPORATION LIMITED**

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

Sl No.	Clause No.	As Existing	As Amended	Reference to Sl. No. of Response [Table 1] wherever applicable
2	Section 3: Evaluation and Qualification Criteria. 2.5(b) DOCUMENTARY EVIDENCES:	Tender Clause: c) As regards documentary proof to substantiate experience requirement in regard to erection work, experience in manufacturing capacity, supply of towers, execution of works and satisfactory operation is concerned, the bidder will have to submit necessary certificates from User Agency clearly specifying the period of experience and other details. (All the certificates for proof should be attested)	As regards documentary proof to substantiate experience requirement as regard to erection work, experience in manufacturing capacity, supply of towers, execution of works and satisfactory operation is concerned, the bidder will have to submit necessary certificates from User Agency clearly specifying the period of experience, scope of work and other details. (All the certificates for proof should be self-attested. however, at the time of contract signing the successful bidder will have to produce notarized documents.	<u>TABLE-1(A):</u> Sl No. 4
3	Section 3: Evaluation and Qualification Criteria page 47, I	The manufacturer should have designed, supplied, erected, tested and commissioned on supply cum erection basis at least 3 (three) nos. GIS installations of 400kV or above voltage level in India during last 7(seven) years having minimum 7 (seven) nos. complete GIS Bays and which should be under satisfactory operation for at least 3 (three) year as on the originally schedule date of tender opening (Certificate of original customer to be submitted). The bidder should list such works executed to substantiate the requirement of this Clause	The manufacturer should have designed, supplied, erected, tested and commissioned on supply cum supervision (erection, testing and commissioning) basis at least 2 (two) nos. GIS installations of 400kV or above voltage level during last 10(Ten) years having minimum 7 (seven) nos. complete GIS Bays and which should be under satisfactory operation for at least 3 (three) year as on the originally schedule date of tender opening (Certificate of original customer to be submitted). The bidder should list such works executed to substantiate the requirement of this Clause	<u>TABLE-1(A):</u> Sl no.6
4	2.4.1 (a) Contract of Similar Size and Nature PART B: (Associated Transmission Lines	The bidder shall submit an undertaking that the tower design, type testing and vetting by CPRI shall be completed within nine (09) months from the date of notification of award (NOA) of work	iii. The bidder shall submit an undertaking that the tower design, type testing and vetting by CPRI/NABL/IIT or equivalent shall be completed within nine (09) months	<u>TABLE-1(A):</u> Sl No. 7

**ASSAM ELECTRICITY GRID CORPORATION LIMITED**

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

Sl No.	Clause No.	As Existing	As Amended	Reference to Sl. No. of Response [Table 1] wherever applicable
	for 400kV, 220kV and 132kV Voltage Level)		from the date of notification of award (NOA) of work.	
5	Section 4: Tender Forms. Tables of Adjustment Data (The Price adjustment shall as per IEEMA PV Calculator) Table A - Local Currency	Table A: Tenderer's Proposed Weighting $\alpha = 0.15$	Tenderer's Proposed Weighting – As per IEEMA	TABLE-1(A): Sl No. 8
6	Section 6: Employer's Requirement, 7. Personnel Requirements	Tender Clause: 5. Community Consultation Officer: Master of Social Work or similar suitable qualification with at least 8 years of experience in Stakeholder Consultations in Assam for linear infrastructure projects. Good understanding of social sensitivities of Assam and community structure and specialized consultation needs would be essential.	Community Consultation Officer: Master of Social Work or similar suitable qualification with at least 8 years of experience in Stakeholder Consultations for linear infrastructure projects. Good understanding of social sensitivities and community structure and specialized consultation needs would be essential. Experience in Assam will be preferable.	TABLE-1(A): Sl No. 9
7	Section 8: Special Condition of Contract, Defect Liability - 27.10 page 196	Extended Warranty The other critical components covered under the extended defect liability period are GIS equipment and the period shall be for five (5) years beyond the defect liability period of the contract (as per clause 27.2 of GCC). The Bidder/GIS manufacturer shall furnish performance guarantee for an amount of 20% of the ex-works cost of GIS equipment(s) for a period of five (5) years to cover the extended defect liability period.	Extended Warranty The other critical components covered under the extended defect liability period are GIS equipment and the period shall be for five (5) years beyond the defect liability period of the contract (as per clause 27.2 of GCC). The Bidder/GIS manufacturer shall furnish performance guarantee for an amount of 10% of the ex-works cost of GIS equipment(s) for a period of five (5) years to cover the extended defect liability period.	TABLE-1(A): Sl No. 14

**ASSAM ELECTRICITY GRID CORPORATION LIMITED**

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (1st FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

Sl No.	Clause No.	As Existing	As Amended	Reference to Sl. No. of Response [Table 1] wherever applicable
8	Section 8: Special Condition of Contract, 13. Securities	<p>13.3.3 For GIS equipment manufactured and supplied, the contractor shall have to extend the Performance BG within one month prior to expiry of the Performance BG furnished for the main contract to cover the extended guarantee period plus two months as part of the contract performance to cover the Contractors extended defect liability in accordance with the provision in the SCC, pursuant to GCC Subclause 27.10.</p> <p>Extended guarantee for the GIS equipment shall be for five (5) years beyond the defect liability period of the contract. The amount of the BG shall be 20% of the GIS equipment cost and shall be in non-Judiciary stamp papers of worth minimum Rs. 100/-</p> <p>However, BG period may be split up subject to the condition that BG would be extended from time to time to cover the warranty period. Moreover, before one month (i.e., 30 days) of expiry of the BG, renewal is to be done by the contractor, otherwise revocation would be done by AEGCL within claim period.</p>	<p>13.3.3 For GIS equipment manufactured and supplied, the contractor shall have to extend the Performance BG within one month prior to expiry of the Performance BG furnished for the main contract to cover the extended guarantee period plus two months as part of the contract performance to cover the Contractors extended defect liability in accordance with the provision in the SCC, pursuant to GCC Subclause 27.10.</p> <p>Extended guarantee for the GIS equipment shall be for five (5) years beyond the defect liability period of the contract. The amount of the BG shall be 10% of the GIS equipment cost and shall be in non-Judiciary stamp papers of worth minimum Rs. 100/-</p> <p>However, BG period may be split up subject to the condition that BG would be extended from time to time to cover the warranty period. Moreover, before one month (i.e., 30 days) of expiry of the BG, renewal is to be done by the contractor, otherwise revocation would be done by AEGCL within claim period.</p>	
9	BOQ		Revised BOQ uploaded	

-Sd-

Project Director (AIIB), AEGCL